REV	LOC	RN	CHANGE	BY	APP. BY	APP. DT
A			ORIGINAL RELEASE			
B		2282	CORRECT SEBB DRAWING	SOR	rm	7/9 02

SEBB-6/24 SYSTEM 3505 BATTERY CHARGER



TOP VIEW



FRONT PANEL VIEW



3505 SYSTEM REAR PANEL



B
4B48E037
CKT #C
(DIGITIZE TO VERIFY CONNECTION PORT)

A
4B48E036
CKT #B

120V AC
CKT #E155C1A-40
CKT I

CONTROLLED
JUL 8 2003
COPY

USED ON NEXT ASS'Y:	DRN 2/4/02 rm	UNLESS OTHERWISE SPECIFIED	DIGITIZE®
	CHK	.000=.005 .00=.015 ANG TOL=1/2°	SEBB-6/24 BATTERY CHARGER SYSTEM 3505
	ENG		
	APP		
	MATERIAL	SCALE	SIZE D 800321 REV B
	DO NOT SCALE THIS DRAWING		SHEET 6 OF 100

PROFESSIONAL SEAL (IF REVISION, APPLIES ONLY TO REVISED WORK)	TITLE 2 CONSTRUCTION 3/29/2005	ISSUE (PROGRESS, ESTIMATE, BID, CONSTRUCTION, CONFORMED, REVISION, RECORD)	REVISION NUMBER	DRAWN BY	CHECKED BY	APPR'D BY	DATE	REMARKS

48 DIGITIZE FIRE ALARM SYS
SEBB-6/24 BATTERY CHARGER
SYSTEM 3505

UNIVERSITY OF CALIFORNIA
LAWRENCE BERKELEY NATIONAL LABORATORY
FACILITIES DIVISION

		DATE
DRAWN BY	AD	3/29/2005
CHECKED BY	MCG	3/29/2005
APPROVED BY	MCG	3/29/2005
CAD FILE PATH	00019137	
SCALE	As Noted	
DRAWING NO.	4B48E046_	SHEET 5 OF 6
PROJECT NO.	FE5011	