KEYED MAINTENANCE SWITCH PLATE LAYOUT TYPICAL 2 PLACES



KEYED MAINTENANCE SWITCH TYPICAL 2 PLACES

(FOR REFERENCE ONLY)

WEATHER PROOF DEVICE DETAIL FOR SOLENOIDS



-FOR REFERENCE ONLY-

WEATHER PROOF MONITOR DEVICE DETAIL



DEVICE
- TAMPER SWITCH
- PRESSURE SWITCH
- FOAM LIQUID LEVEL - LOW
- FOAM LIQUID LEVEL - MEDIUM
- FOAM LIQUID LEVEL - HIGH

-FOR REFERENCE ONLY-

FIRE ALARM DEVICES WIRING DETAIL LAYOUT

EXPLOSION PROOF START/STOP WIRING DETAIL



-FOR REFERENCE ONLY-

EXPLOSION PROOF MANUAL PULL STATION WIRING DETAIL



-FOR REFERENCE ONLY-

EXPLOSION PROOF JUNCTION BOX WITH COVERS DETAIL



-FOR REFERENCE ONLY-

EXPLOSION PROOF HEAT DETECTOR MOUNTING DETAIL



LEGEND
1 - HEAT DETECTOR E.P.
2 - E.P. BOX
3 - RIGID STEEL (CONDUIT) EXPLOSION PROOF
4 - CEILING

-FOR REFERENCE ONLY-

4S JUNCTION BOX MONITORING DEVICE DETAIL



DEVICE
- TAMPER SWITCH
- WATER FLOW SWITH

-FOR REFERENCE ONLY-

TRI-SIGNAL,INC
CERT. CALIFORNIA A-42
GLADSTONE, CA 91024
PH:(626)963-8127-1291
FAX: (626)963-8128
LICENSE: 00000070

T. NELSON
W. CORCIO

UNIVERSITY OF CALIFORNIA, BERKELEY
LAWRENCE BERKELEY LABORATORY, TOXICS MANAGEMENT WASTE MANAGEMENT FACILITY
BERKELEY, CA

WIRING DETAIL LAYOUTS
BUILDING FIRE ALARM DETECTION & AFFF FIRE SUPPRESSION SYSTEM

94-171-007 4N85E044E
NOT TO SCALE 7 OF 16

REVISIONS