

RUN	TAP	MOLD
4/0	4/0	XAC–2Q2Q
4/0	2/0	XAC–2Q2G
4/0	2	XAC–2Q1V

5 CROSS OF HORIZONTAL CABLE

LBNL ELECTRICAL STANDARDS
GROUNDING
CROSS OF HORIZONTAL CABLE

DRAWN BY	DATE
CHECKED BY	
APPROVED BY	
CAD FILE PATH	
SCALE NTS	
DRAWING NO. GRD105	SHEET
PROJECT NO.	

UNIVERSITY OF CALIFORNIA LAWRENCE BERKELEY NATIONAL LABORATORY
FACILITIES DIVISION

T:\groups\ELECT\Romy\STD\Grounding\GRD105 CROSS OF HORIZONTAL CABLE.dwg