



ELEVATION NOTES

1. THIS DRAWING IS FOR DIAGRAMMATIC PURPOSES ONLY. FOR ACTUAL HANDING AND SWING, REFERENCE FLOOR PLANS.
2. DIMENSIONS SHOWN FOR COORDINATION ONLY. EXACT LOCATIONS AND MOUNTING HEIGHTS TO BE FIELD COORDINATED WITH OWNER AND ARCHITECT.
- 3 IF INSTALLATION IS ABOVE A FINISHED CEILING, CONDUIT IS NOT REQUIRED FOR THIS CABLE RUN. USE PLENUM CABLE.
- 4 IF INSTALLATION IS ABOVE A FINISHED CEILING, STUB CONDUIT, w/PULL STRING, 6" ABOVE FINISHED CEILING.
5. ALL CONDUIT IS 3/4" UNLESS OTHERWISE NOTED.
- 6 MOUNT 10"x10"x4" JUNCTION BOX ON THE SECURED SIDE BEHIND THE CARD READER. IF FIELD CONDITIONS PROHIBIT INSTALLATION, MOUNT PER FACILITIES ELECTRONICS SHOP APPROVED LOCATION.

NP-5 | ROLL-UP DOOR, CARD READER TOGGLE ON/OFF
ALARMED
ELEVATION

SCALE: N.T.S.

LBNL ELECTRICAL STANDARDS
SECURITY CARD ACCESS NP-5
ROLL-UP DOOR, CARD READER TOGGLE ON/OFF

DRAWN BY	DATE
CHECKED BY	
APPROVED BY	
CAD FILE PATH	
SCALE	NTS
DRAWING NO.	SHEET
SEC116A	NP-5
PROJECT NO.	

UNIVERSITY OF CALIFORNIA LAWRENCE BERKELEY NATIONAL LABORATORY
FACILITIES DIVISION