

SECURE FAN CURB BASE TO CURB WITH 3/8"Ø BOLTS WITH LEAD WASHERS. TWO PER SIDE ON VERTICAL EDGE

CANT AROUND

ROOFING

#10 SHEET METAL SCREWS MIN. THREE PER SIDE

ACOUSTIC DUCT LINING

EXHAUST FAN

BACK DRAFT DAMPER

1/4" MOUNTING BOLTS 6" O.C. AROUND

FLUSHING


MOUNTING CURB

(E) METAL DECK

STEEL SUB. FRAMING SEE STRUCT. DWG.

DUCT THRU ROOF

- NOTES: ① FIELD VERIFY EXACT WIDTH OF CURB TO FIT FAN MOUNTING BASE  
 ② NEOPRENE GASKET AROUND



**ROOF EXHAUST FAN**

SCALE: NONE

LBNL STANDARD  
 ROOF EXHAUST FAN

DRAWN BY	DATE
CHECKED BY	
APPROVED BY	
CAD FILE PATH	
SCALE	NTS
DRAWING NO.	SHEET
H 1 4 2	
PROJECT NO.	

UNIVERSITY OF CALIFORNIA LAWRENCE BERKELEY NATIONAL LABORATORY  
 FACILITIES DIVISION