(N) RETURN/EXHAUST AIR BLOWER					
EQUIPMENT NO.	ROOM	CFM	HP	VOLT/PHASE/HZ	MODEL
BL-182-70	3/F	3020 AT 0.5" WG ESP	3	208V/3ø/60HZ	TWIN CITY INLINE BLOWER TYPE TSL 122 20"øx 26"L x 33"H

X
XX

RETURN/EXHAUST AIR BLOWER SCHEDULE

SCALE: NONE

LBNL STANDARD

RETURN/EXHAUST BLOWER SCHEDULE

UNIVERSITY OF CALIFORNIA LAWRENCE BERKELEY NATIONAL LABORATORY

FACILITIES DIVISION

DRAWN BY		DATE
CHECKED BY		
APPROVED BY		
CAD FILE PATH		
SCALE	NTS	
DRAWING NO.	SCH105	SHEET
PROJECT NO.		

T:\groups\ELECT\Romy\Mech_IHEM\Standard_Schedules\SCH105 RETURN-EXHAUST-BLOWER-SCHEDULE.dwg